

# **CONTOIL®**


## **DN 4 - 8**

**Measurement**

# CONTOIL®

## Fuel oil meters DN 4 - 8 (12)

Fuel consumption measurement for trucks, buses, trains, construction and agricultural machinery, small boats and generators as well as for burners.



### Features:

- » Supports most used models of vehicles
- » Proved and tested system
- » Easy and accurate reading of engine fuel consumption
- » No extra maintenance necessary
- » Tamper-proof measurement

### Benefits:

- » Low installation costs
- » Quick and easy installation
- » Short down-time of vehicle
- » Quick pay-back period



# CONTENT

Introduction	4
Operating principle	5
Product range	6
Technical specifications	8
Project planning notes	25
Installation	27
Warranty, safety instructions	30



# INTRODUCTION

Thank you for your decision to work with Aquametro Oil & Marine Fuel Measurement Products.  
This technical specification describes the installation, commissioning and use of CONTOIL® fuel oil meters.

## Liability Disclaimer

The manufacturer cannot monitor the compliance to this manual as well as the conditions and methods during the installation, operation, usage and maintenance of the system regulator. Improper installation can cause damage and endanger people. Therefore, we assume no responsibility and liability for losses, damage or costs that result due to incorrect installation, improper operation, usage and maintenance or in any manner associated therewith. Similarly, we assume no responsibility for patent right or other right infringements of third parties caused by usage of this system regulator. The manufacturer reserves the right, without prior notification, to make modifications concerning the product, technical data or installation and operating manual.

## Safety precautions

CONTOIL® fuel oil meters must only be used for their intended purpose and comply with local and international safety regulations. All documentation is to be followed exactly. None of the information stated here or elsewhere releases planners, installers and operators from their own careful and comprehensive assessment of the respective plant configuration in terms of functional capability and operational safety.

- » Local applicable working regulations must be complied with, during all work on the plant and/or ship.
- » All safety, installation and operation instructions as described in this manual must be followed.
- » Sensors are sensitive measuring instruments and should be treated carefully.



# OPERATING PRINCIPLE

## Function

CONTOIL® fuel oil meters work on the volumetric principle of rotary piston meters (positive displacement meters). The main features of this measuring principle are large measuring ranges, high accuracy, suitability for high viscosities and independence from power supply; flow disturbances do not influence proper operation.



Leading manufacturers of oil burners and operators of heating systems, ships or diesel engines rely on CONTOIL® fuel oil meters - and with good reasons.

### Advantages:


- » Optimal solution for every application
- » Can be mounted on the pressure or suction side of a pump
- » Space-saving installation, because no straight inlet / outlet sections are required
- » Flexible mounting of the meter in horizontal, vertical or inclined positions
- » Accurate measurement result, since the reading is independent of the temperature and viscosity of the fluid
- » Minimum failure costs due to simple function monitoring, rapid fault analysis and the possibility of simple repairs on site

### Areas of application:

- » To measure fuel consumption of oil burners (e. g. in heating boilers, industrial furnaces, tar processing plants)
- » Consumption monitoring and optimisation (ships, generators, etc)
- » Flow measurement for mineral oils
- » Optional remote processing and integration into superior systems
- » Manual dosing / filling / batch processing

### Fuel types:

- » Fluids according to ISO 8217-2010
- » Heating fuel extra light / light



# PRODUCT RANGE

## CONTOIL® fuel oil meters DN 4 - 8 (12)

### Fuel oil meters for direct fuel measurement


#### Hydraulic

##### **VZO 4 Qmin / VZO 4 + 8 / VZO 4 + 8 OEM**

Hydraulic connections  $\frac{1}{8}$ " and M14x1.5

#### Main characteristics:

- » Optimal flow range 0.5 - 200 l/h
- » Temperature ranges -30 to +80 °C
- » Nominal pressure PN 25



#### Electronic read out

##### **VZO 4 + 8 RE / VZO 4 + 8 OEM**

- » Output signals for: RE and VZO OEM

For more information, see page 8


#### Hydraulic

##### **VZD/VZP 4 + 8**

Hydraulic connections  $\frac{1}{8}$ " and M14x1.5

#### Main characteristics:

- » Optimal flow range 1 - 200 l/h
- » Temperature ranges -30 to +80 °C
- » Nominal pressure PN 25



#### Electronic read out

##### **VZD / VZP 4 + 8**

- » Electronic display of: VZD
- » Output signals for: VZD / VZP

For more information, see page 12

## Fuel oil meters for differential fuel measurement

### Hydraulic

#### DFM 8D

Hydraulic connections M14x1.5

#### Main characteristics:

- » Optimal flow range 10 - 260 l/h
- » Temperature ranges -30 to +80 °C
- » Nominal pressure PN 16 bar



#### DFM 8ECO / DFM 8EDM / DFM 12ECO

Hydraulic connections M14x1.5

#### Main characteristics:

- » Optimal flow range 10 - 600 l/h
- » Temperature ranges -30 to +80 °C
- » Nominal pressure PN 16 bar



### Electronic read out


#### DFM 8D / DFM 8ECO / DFM 8EDM / DFM 12ECO

- » Output signals for: DFM 8 + 12

For more information, see page 16

# TECHNICAL SPECIFICATIONS

## Technical data CONTOIL® VZO 4 Hydraulic



Hydraulic			VZO 4	VZO 4 Qmin	VZO 4 OEM
<b>Nominal diameter</b>	<b>DN</b>	<b>mm</b>	<b>4</b>	<b>4</b>	<b>4</b>
		inch	1/8	1/8	1/8
Hydraulic connection	G <sup>1)</sup>	inch	1/8	1/8	1/8
Nominal pressure	PN	bar	25	25	25
Max. medium temperature	T <sub>max</sub>	°C	-30 to +80	-30 to +80	-30 to +80
Max. environmental temperature		°C	-10 to + 60	-10 to + 60	-10 to + 60
Max. storage temperature		°C	-40 to +85	-40 to +85	-40 to +85
Protection class	IP		50	50	65
Maximum flow rate	Q <sub>max</sub>	l/h	80	40	80
<b>Continuous flow rate</b>	<b>Q<sub>cont</sub></b>	<b>l/h</b>	<b>50</b>	<b>25</b>	<b>50</b>
Minimum flow rate	Q <sub>min</sub>	l/h	1	0.5	1
Approx. starting flow rate		l/h	0.4	0.3	0.4
Max. permissible error of actual value			<±1.0 % <sup>2)</sup>	<±1.0 % <sup>2)</sup>	<±1.0 % <sup>2)</sup>
Repeatability			<±0.2 %	<±0.2 %	<±0.2 %
Measuring chamber volume		cm <sup>3</sup>	5	5	5
Fuel			diesel and low viscosity fuels		
Max. viscosity		cSt	6	6	6
Safety filter mesh size		mm	0.125	0.125	-
Weight		kg	0.65	0.65	0.65
Housing finish			brass gold color		

1) G-threads have a parallel shape in accordance with the DIN-EN-ISO 228-1 standard with flank angle 55°.

2) 0.5 - 1 l/h ±5 %; 1 - 2 l/h ±2.5 %



## Technical data

### CONTOIL® VZO 8

#### Hydraulic



Hydraulic		VZO 8		VZO 8 OEM
Nominal diameter	DN	mm inch	8 1/4	8 1/4
Hydraulic connection			G <sup>1)</sup> 1/4 inch	M14x1.5 mm
Nominal pressure	PN	bar	25	25
Max. medium temperature	T <sub>max</sub>	°C	-30 to +80	-30 to +80
Max. environmental temperature		°C	-10 to +60	-10 to +60
Max. storage temperature		°C	-40 to +85	-40 to +85
Protection class	IP		50	65
Maximum flow rate	Q <sub>max</sub>	l/h	200	200
<b>Continuous flow rate</b>	<b>Q<sub>cont</sub></b>	<b>l/h</b>	<b>140</b>	<b>140</b>
Minimum flow rate	Q <sub>min</sub>	l/h	4	4
Approx. starting flow rate		l/h	1.6	1.6
Max. permissible error of actual value			<±1.0 <sup>2)</sup>	<±1.0 % <sup>2)</sup>
Repeatability			<±0.2 %	<±0.2 %
Measuring chamber volume		cm <sup>3</sup>	12.44	12.44
Fuel			diesel and low viscosity fuels	
Max. viscosity		cSt	6	6
Safety filter mesh size		mm	0.15	0.15
Weight		kg	0.75	0.75
Housing finish			brass gold color	

1) G-threads have a parallel shape in accordance with the DIN-EN-ISO 228-1 standard with flank angle 55°.

2) 4 - 5 l/h ±2 %



## Technical data

### CONTOIL® VZO 4 + 8

#### Electrical and output specifications

Electronic			VZO 4	VZO 8	VZO 4 OEM	VZO 8 OEM
Reed pulser						
RE 1	I/pulse	-		◀▶	-	-
RE 0.1	I/pulse	◀▶	-	-	-	-
RE 0.00125	I/pulse	◀▶	-	-	-	-
RE 0.00311	I/pulse	-		◀▶	-	-
Pulse frequency						
RE 0.00125	at Q <sub>max</sub>	Hz	17.777	-	-	-
	at Q <sub>min</sub>	Hz	0.222	-	-	-
RE 0.00311	at Q <sub>max</sub>	Hz	-	17.864	-	-
	at Q <sub>min</sub>	Hz	-	0.357	-	-
Reed pulser RE			I/pulse		0.005	0.01244
Pulse frequency RE	at Q <sub>max</sub>	Hz			4.444	4.444
	at Q <sub>min</sub>	Hz			0.056	0.089

Electronic CONTOIL® VZO 4 + 8		REED pulser
Switching element	Reed switch with dry contact (inert gas)	
Switching voltage	Max. 48 VAC/DC, protection class III (SELV)	
Switching current	Max. 50 mA	
Quiescent current	Open contact	
Switching power	Max. 2 W	
ON-time	VZO 4-RE 0.00125:	30 - 70 % (17 - 39 ms at 80 l/h)
	VZO 4-RE 0.1:	40 - 60 %
	VZO 8-RE 0.00311:	30 - 70 % (17 - 39 ms at 200 l/h)
	VZO 8-RE 1:	40 - 60 %
Protection class	IP 50 (IEC 60529) against harmful dust deposits Option: IP 54 additional against splashing water	
Connections	Plug on connector with cable 3.5 - 5 mm Ø	

Electronic CONTOIL® VZO 4 + 8 OEM	REED pulser
Switching element	Reed switch with dry contact (inert gas)
Switching voltage	Max. 230 VAC/DC
Switching current	Max. 50 mA
Quiescent current	Open contact
Switching power	Max. 3 VA
ON-time	40 - 55 %
Protection class	IP 65 (IEC 60529) against dust and water jets
Connections	Cable cross section 2 x 0.5 mm <sup>2</sup> , length 480 mm

### Safety note

When connecting the Reed pulser to a low-voltage power source (50 - 250 VAC/DC), the specialist installing the equipment is responsible for ensuring that all local regulations are observed (e. g. regulations for electrical installations, personnel safety).

Avoid disturbance of electromagnetic fields.



## Technical data

### CONTOIL® VZD/VZP 4

### Hydraulic



Hydraulic		VZD 4		VZP 4
<b>Nominal diameter</b>	<b>DN</b>	<b>mm</b>	<b>4</b>	<b>4</b>
		inch	1/8	1/8
Hydraulic connection	G <sup>1)</sup>	inch	1/8	1/8
Nominal pressure	PN	bar	25	25
Max. medium temperature	T <sub>max</sub>	°C	-30 to +80	-30 to +80
Max. environmental temperature <sup>2)</sup>		°C	-20 to +60	-
Max. storage temperature		°C	-40 to +85	-40 to +85
Protection class	IP		66	66
Maximum flow rate	Q <sub>max</sub>	l/h	80	80
<b>Continuous flow rate</b>	<b>Q<sub>cont</sub></b>	<b>l/h</b>	<b>50</b>	<b>50</b>
Minimum flow rate	Q <sub>min</sub>	l/h	1	1
Approx. starting flow rate		l/h	0.4	0.4
Max. permissible error of actual value			<±1.0 % <sup>3)</sup>	<±1.0 % <sup>3)</sup>
Repeatability			<±0.2 %	<±0.2 %
Measuring chamber volume		cm <sup>3</sup>	5	5
Fuel			diesel and low viscosity fuels	
Max. viscosity		cSt	6	6
Safety filter mesh size		mm	0.125	0.125
Weight		kg	0.65	0.65
Housing finish			brass gold color	

1) G-threads have a parallel shape in accordance with the DIN-EN-ISO 228-1 standard with flank angle 55°.

2) If the device is used below or above stated temperature rating, the LCD can react slower and life time can be shortened.

3) 0.5 - 1 l/h ±5 %; 1 - 2 l/h ±2.5 %

# Technical data **CONTOIL® VZD/VZP 8** Hydraulic



Hydraulic			VZD 8	VZP 8
<b>Nominal diameter</b>	<b>DN</b>	<b>mm</b>	<b>8</b>	<b>8</b>
		inch	1/4	1/4
Hydraulic connection		mm	M14x1.5	M14x1.5
Nominal pressure	PN	bar	25	25
Max. medium temperature	T <sub>max</sub>	°C	-30 to +80	-30 to +80
Max. environmental temperature <sup>1)</sup>		°C	-20 to +60	-
Max. storage temperature		°C	-40 to +85	-40 to +85
Protection class	IP		66	66
Maximum flow rate	Q <sub>max</sub>	l/h	200	200
<b>Continuous flow rate</b>	<b>Q<sub>cont</sub></b>	<b>l/h</b>	<b>140</b>	<b>140</b>
Minimum flow rate	Q <sub>min</sub>	l/h	4	4
Approx. starting flow rate		l/h	1.6	1.6
Max. permissible error of actual value			<±1.0 % <sup>2)</sup>	<±1.0 % <sup>2)</sup>
Repeatability			<±0.2 %	<±0.2 %
Measuring chamber volume		cm <sup>3</sup>	12.44	12.44
Fuel			diesel and low viscosity fuels	
Max. viscosity		cSt	6	6
Safety filter mesh size		mm	0.15	0.15
Weight		kg	0.75	0.65
Housing finish			brass gold color	

1) If the device is used below or above stated temperature rating, the LCD can react slower and life time can be shortened.

2) 4 - 5 l/h ±2 %

## Technical data

### CONTOIL® VZD/VZP 4 + 8


#### Electrical and output specifications

Electronic		VZD 4	VZP 4
Pulse value (HI-Res)	I/pulse	0.005	0.005
Pulse value (Param)	I/pulse	0.150	-
Pulse width (HI-Res)	ms	20	20
Pulse width (Param)	ms	1'000	-
Current load (open drain output) max.	mA	50	50
Output operational voltage max.	VDC	48	48
Output dropout voltage		max. 2 VDC at 50 mA	
Power supply	VDC	12 - 24	12 - 24
Amplitude range		equal to power supply	


Electronic		VZD 8	VZP 8
Pulse value (HI-Res)	I/pulse	0.01244	0.01244
Pulse value (Param)	I/pulse	0.150	-
Pulse width (HI-Res)	ms	20	20
Pulse width (Param)	ms	1'000	-
Current load (open drain output) max.	mA	50	50
Output operational voltage max.	VDC	48	48
Output dropout voltage		max. 2 VDC at 50 mA	
Power supply	VDC	12 - 24	12 - 24
Amplitude range		equal to power supply	

## Functional diagramm CONTOIL® VZD/VZP 4 + 8 electrical and output specification


CONTOIL® VZD 4/8




CONTOIL® VZP 4/8



### Output signal specification



### Short view of the menu



#### Main menu

- » Total, trip, current consumption
- » Info, service
- » Logger data, error data, display test

#### Info/Service menu

- » Idle/working mode, operation hours, unit
- » Battery capacity, fuel temperature, RESET mode
- » Correction factor, password
- » Current CO<sub>2</sub> emission, total CO<sub>2</sub> emission
- » Min. flow rate, max. flow rate
- » Date, time


The complete menu is shown in the Mounting and operating instructions.



## Technical data

### CONTOIL® DFM 8 + 12

#### Hydraulic



Hydraulic			DFM 8 D	DFM 8 EDM	DFM 8 ECO	DFM 12 ECO
Nominal diameter	DN	mm	8	8	8	12
		inch	1/4	1/4	1/4	1/4
Hydraulic connection		mm	M14x1.5	M14x1.5	M14x1.5	M14x1.5
Nominal pressure	PN	bar	16	16	16	16
Max. medium temperature	T <sub>max</sub>	°C	-30 to +80	-30 to +80	-30 to +80	-30 to +80
Max. environmental temperature		°C	-20 to +80	-20 to +80	-20 to +80	-20 to +80
Max. storage temperature		°C	-40 to +85	-40 to +85	-40 to +85	-40 to +85
Protection class	IP		66	66	66	66
Maximum flow rate	Q <sub>max</sub>	l/h	260	260	260	600
<b>Continuous flow rate</b>	<b>Q<sub>cont</sub></b>	<b>l/h</b>	<b>200</b>	<b>200</b>	<b>200</b>	<b>400</b>
Minimum flow rate	Q <sub>min</sub>	l/h	10	10	10	10
Approx. starting flow rate		l/h	0.4	0.4	0.4	0.4
Max. permissible error of actual value			<±1.0 %	<±1.0 %	<±1.0 %	<±1.0 %
Repeatability			<±0.2 %	<±0.2 %	<±0.2 %	<±0.2 %
Measuring chamber volume		cm <sup>3</sup>	12.44	12.44	12.44	12.44
Fuel			diesel and low viscosity fuels			
Max. viscosity		cSt	6	6	6	6
Safety filter mesh size		mm	-	-	0.15	0.15
Weight		kg	0.65	0.65	0.65	0.65
Housing finish			brass gold color			




## Technical data

### CONTOIL® DFM 8 + 12


#### Electrical and output specifications

Electronic		DFM 8 D	DFM 8 EDM	DFM 8 ECO	DFM 12 ECO
Pulse value	I/pulse	0.01244	0.01244	0.01244	0.01244
Frequency at Q <sub>cont</sub>	Hz max	<4.5	<4.5	<4.5	<9
Pulse width	ms	20	20	20	20
Current load (open drain output) max.	mA	50	50	50	50
Power supply	VDC	12 - 24	12 - 24	12 - 24	12 - 24
Amplitude range	equal to power supply				

**Functional diagramm passive output**




**Output signal specification**



### Functional diagramm CONTOIL® DFM 8 EDM pulse specification; passive pulse

Whenever a pulse is generated, the electronic switch at the DFM 8 EDM will be closed and the incoming 12 - 24 VDC will be redirected to the external device.




TTL Pulse:

Below 0.8 VDC = pulse (logic 0)


Between 0.8 - 2.8 VDC is not defined


Over 2.8 VDC = no pulse (logic 1)



### Functional diagramm CONTOIL® DFM 8 / 12 ECO pulse specification; passive pulse


Whenever a pulse is generated, the electronic switch at the DFM 8 / 12 ECO will be closed and the incoming 12 - 24 VDC will be redirected to the external device.






## Dimensional drawings (all dimensions in mm)


### CONTOIL® VZO 4 + 8





### CONTOIL® VZO 4 + 8 RE





### CONTOIL® VZO 4 OEM





**CONTOIL® VZO 8 OEM**





**CONTOIL® VZD/VZP 4**




**CONTOIL® VZD/VZP 8**




**CONTOIL® DFM 8 D / DFM 8 EDM****CONTOIL® DFM 8 ECO / DFM 12 ECO**

## Pressure drop curves

**CONTOIL® VZD/VZP 4, VZO 4 Q<sub>min</sub>,  
VZO 4, VZO 4 OEM**



**CONTOIL® VZD/VZP 8, VZO 8,  
VZO 8 OEM, DFM 8 D, DFM 8 EDM,  
DFM 8 ECO, DFM 12 ECO**



### Viscosity diagrams:





A = 5 mPas

B = 50 mPas


For a pressure drop of more than 1 bar, it is recommended to use the next larger meter size.



Accessories


VZO 4 + 8	Description		Art. No.
	Threaded connections kit	PS-Kit VZO 4 1/8" - 8	81583
	Mounting kit	PS-Kit VZO 8	81130
	Mounting kit <sup>1)</sup>	VSR-SET VZD/VZP 4 1/8" to M14x1.5	80630
	Threaded connections to suit PS-Kit VZO 8	VSR 3/8"	81156

1) 2 sets needed for one flow meter.

DFM	Description		Art. No.
	Hose connector <sup>1)</sup> include 1 hollow union, 1 single banjo body, 2 copper seals	DFM 8 D, DFM 8 EDM, DFM 8 ECO, DFM 12 ECO	80447

1) 4 sets needed for one DFM 8 D, DFM 8 EDM, DFM 8 ECO, DFM 12 ECO.

Mounting kit for VZO 8 - dimensions and some possible mounting positions  
(all dimensions in mm)







# PROJECT PLANNING NOTES

## Project Application - Burner

### Mounting on pressure side of pump



### Mounting on suction side of pump



### Indicative values on power for burners

Burner			Flow meter	
Power	Flow rate heating fuel		Flow rate $Q_{min} - Q_{cont}$	Nominal diameter
up to kW	kg/h	l/h	l/h	DN
500	42	50	1 - 50	4
1300	113	135	4 - 140	8
4000	336	400	10 - 400	12

Formula for consumption in litres/hour:

Burner power in kW

Energy value of fuel in kWh/kg x density in kg/dm<sup>3</sup>

Example:


4000 kW

$= 4000 : 9.912 = 403 \text{ l/h}$


11.8 kWh/kg x 0.84 kg/dm<sup>3</sup>

## Project Application - Engine

### Direct measurement



### Differential measurement



### Indicative values on power for engines

Engine			Flow meter <sup>1)</sup>	
Power	Diesel fuel consumption		Flow rate $Q_{min} - Q_{cont}$	Nominal diameter
up to HP	up to kW	l/h	l/h	DN
250	184	50	1 - 50	4
680	500	135	4 - 140	8
2000	1470	400	10 - 400	12

1) For differential measurement the flow meter has to be selected according to the pump flow rate in supply and the flow in the return pipe.

Formula:  $1 \text{ DIN-HP} = 0.736 \text{ kW}$        $1 \text{ kg Diesel at } 0.84 \text{ kg/dm}^3 = 1.19 \text{ l}$   
 $1 \text{ kW} = 1.36 \text{ DIN-HP}$

Rule of thumb: approx. 190 g Diesel/kWh correspond to 0.226 l Diesel/kWh  
 approx. 140 g Diesel/HP correspond to 0.167 l Diesel/HP

# INSTALLATION


## Planning

Flow meters are precision measuring instruments. They achieve optimal results if

- » a few important rules are observed during plant design,
- » mounting and commissioning are carried out with care,
- » the meters are used for their defined purpose only.

## Layout of pipework

- » The quantities consumed by all consumers must be registered by the meter.
- » Rotary piston meters do not require flow conditioners or inlet runs (after bends, T-pieces or fittings). They may be mounted in horizontal, vertical or inclined position, except with the head pointing downwards.
- » The layout of piping must ensure that the meter is at all times filled with liquid and that no inclusions of air or gas may occur. Do not install the instrument at the highest point of the installation.
- » Meter and accessory equipment must be easily accessible.



## Selection of the meter and ancillaries

To be considered when selecting the meter:

- » Operating temperature
- » Viscosity of the medium
- » Operating pressure
- » Flow rate
- » Resistance of the material against fuel to be metered and working conditions

The technical data are valid for the following reference conditions: EL heating fuel/diesel at 20 °C. For higher viscosities or if the meter is mounted on the suction side of a pump, it is necessary to determine the pressure drop and the flow rate that can still be attained by using the pressure loss curves. If the pressure drop is more than 1 bar, it is advised to use the next larger meter size.

## Dirt filter, safety filter

Filters are any way required in the system to protect engines and pumps to keep their performance and live time. For fuel oil meters this is no different - that's why we recommend installing the fuel oil meters (in flow direction) always directly after the filter. Some particles in the fuel are also from engine's wear and tear, that's why we also recommend a filter in the fuel return line. Usually basket type filters are best choice for the return line and automatic filters in the supply line. Major engine producers recommend a mesh size of 5 - 10  $\mu\text{m}$  (automatic filters), especially to filter out very abrasive cut fines. It is best for the flow meter to install it between this automatic filter and the engine. The maximum filter mesh size for a respective meter can be found in below table.

Examples of filter:

### Maximum mesh width for filters


#### Nominal diameter

DN 4	0.08 mm
DN 8	0.1 mm

- » The filter mounted in the meter inlet is only a safety filter and is too small to act as a dirt filter.
- » If a dirt filter with the given mesh size is used, the safety filter in the meter inlet may be removed.


## Stop valves or non-return valves

In order to avoid backflow and draining, stop valves have to be mounted after the meter. Backflow and draining cause measuring errors and can damage the meter.



## Filling / Dosing

For filling and dosing the valve has to be mounted between meter and outlet. The shorter the pipe section between meter and outlet, the higher the accuracy. Fast opening and shutting of the valve should be avoided (pressure hammer!).



## Remote Processing / Ancillaries

Any backflow must be avoided on meters equipped with pulsers for remote processing. If this cannot be achieved by appropriate plant design, a non-return valve should be fitted.

### Electrical wiring and installations

Electrical wiring and installations are subject to statutory regulations which must be taken into account when planning the system. For installations in zones subject to explosion hazards, consult an appropriate expert.

The following factors should be taken into account during plant design:

- » ancillaries connected to the meter
- » environmental interference
- » maximum permissible cable lengths (with or without amplifier)
- » junction boxes, cable guides



# WARRANTY, SAFETY INSTRUCTIONS

## Warranty Disclaimer

Aquametro Oil & Marine guarantees the quality of the product in the context of its General Terms of Business. The owner, operator or installer will be liable for the correct installation as well as the appropriate handling of the equipment upon its receipt.

- » Please observe the application, mounting and operating instructions.
- » Use the unit exclusively for its designed purpose.
- » Maintain the unit and service it according to prescriptions.
- » Use accessories only if their applicability is technically safe.

## Safety rules and precautionary measures

The manufacturer accepts no responsibility if the following safety rules and precautions are disregarded.

- » Modifications of the device implemented without preceding written consent from the manufacturer, will result in the immediate termination of product liability and warranty period.
- » Installation, operation, maintenance and decommissioning of this device must be carried out by trained, qualified specialists, authorized by the manufacturer, operator or owner of the facility. The specialist must have read and understood these mounting and operating instructions and must follow the instructions here in.
- » Check the voltage and the information on the type plate before installing the device.
- » Check all connections, settings and technical specifications of peripherals which may be present.
- » Open the housing or parts of housings, which electric or electronic components included, only when the electric power is turned off.
- » Do not touch any electronic components (ESD sensitivity).
- » Expose the system with respect to the mechanical load (pressure, temperature, IP protection, etc.), only to a maximum of the specified classifications.
- » During operations that involve mechanical components of the system, release the pressure in the pipe system or reduce the temperature of the medium to a safe level for humans.
- » None of the information stated here or elsewhere releases planners, installers and operators from their own careful and comprehensive assessment of the respective system configuration in terms of functional capability and operational safety.
- » The local labour and safety laws and regulations must be observed.





Distribué par :

**Compteur-énergie**.com

Tel : +33 (0)360 800 010

Mail : [contact@compteur-energie.com](mailto:contact@compteur-energie.com)