


Subject to change without prior notice / Änderungen vorbehalten
Soggetto a modifiche senza preavviso / Susceptible de modification sans préavis / Sujeto a modificaciones sin aviso previo

PICTURE/FIGURE

K



EN - 6A THREE PHASE ENERGY METER

For the communication protocols, please contact the Manufacturer.

BALANCE COUNTER VALUES CALCULATION

BALANCE COUNTER	FORMULA
kWh	$(kWh\ T1) - (kWh\ T1) - (kWh\ T2) - (kWh\ T2)$
kVAh ind	$(kVAh\ ind\ T1) - (kVAh\ ind\ T1) - (kVAh\ ind\ T2) - (kVAh\ ind\ T2)$
kVAh cap	$(kVAh\ cap\ T1) - (kVAh\ cap\ T1) + (kVAh\ cap\ T2) - (kVAh\ cap\ T2)$
kvarh ind	$(kvarh\ ind\ T1) - (kvarh\ ind\ T1) + (kvarh\ ind\ T2) - (kvarh\ ind\ T2)$
kvarh cap	$(kvarh\ cap\ T1) - (kvarh\ cap\ T1) + (kvarh\ cap\ T2) - (kvarh\ cap\ T2)$

KEY FUNCTIONS

Some functions are available according to the device package.

HOW TO	WHERE	KEY	PRESS TIME
Scroll loops	Any page except for Setup 1/2	↔	Instantaneous
Scroll pages in a loop	Any loops page	↕	Instantaneous
Display secondary value for 10 s	Any energy counter page	↕	>3 s
Access Setup 1 pages	"Setup1" page	↕	>3 s
Access Setup 2 pages	Any page except for Setup 1	↕	>3 s
Change a value/digit	Setup 1/2 pages	↕	Instantaneous
Confirm a value/digit	Setup 1/2 pages	↕	Instantaneous
Change counter to be reset	Reset page in Setup 2	↕	Continuous
Exit Setup 1/2 pages	Setup 1/2 pages	↕	>3 s
Start/stop the displayed partial counter	Partial counters pages	↕	Instantaneous
Reset the displayed partial counter value	Partial counters pages	↕	>3 s
Display test	Any page except for Setup 1/2	↕	>10 s

PAGE STRUCTURE

Up to 8 page loops can be displayed (refer to picture K). Some loops can be unavailable according to the device model.

Press **↕** to scroll pages in a loop.

NOTE: in case of 3 wire connection, pages showing phase values are not available. For MID S package, reactive energy counters are not displayed.

HOW TO DISPLAY THE COUNTER SECONDARY VALUE

Feature available only on counter pages.

By pressing **↕** key for 3 s, CT secondary measurements will be shown on display (refer to picture L). To scroll energy values, refer to section "PAGE STRUCTURE". After 10 s keyboard idle, the counter will show again CT primary data.

HOW TO START / STOP / RESET PARTIAL COUNTERS

Feature available only on partial counter pages.

To start, stop or reset a partial counter, refer to the following procedures shown in picture M:

- Procedure to start the displayed partial counter
- Procedure to stop the displayed partial counter previously started
- Procedure to reset the displayed partial counter

In **START?**, **STOP?**, **RESET?** pages, selectable items are: Y-to confirm, N-to cancel. To change item, press **↕**.

SETUP PAGES (pictures N, O)

Some setup pages can be unavailable according to the device model/package.

From any setup value page:

- Press **↕**, the digit/item will start to flash.
- Press **↕** to change the value and confirm with **↕** (repeat this procedure for the next digits, if any).

From partial counter reset or set default page:

- Press **↕**, a new page for confirmation will be displayed.
- Press **↕** to change the flashing value, Y to confirm the reset, N to cancel. Confirm with **↕**.

From energy counter reset page (only package RESET):

ALL or 001...120 range are the possible selections:

• ALL - allows to reset all values relevant to a specific counter group. Each counter group can be identified by symbols on display (L-/->, T1/T2).

• 001...120 - allows to reset the value relevant to a single counter. Each counter can be identified by symbols on display (L-/->, L1/L2/L3, T1/T2, measure unit, ±, ...).

The first six pages are relevant to counter groups (ALL) and displayed according to the following order: tariff 1 imported energy / tariff 1 exported energy / tariff 2 imported energy / tariff 2 exported energy / total imported energy / total exported energy.

The next pages are relevant to single counters (001...120).

NOTE: in case of 3 wire connection, the phase values are not available. For this reason, the counters to be reset within 001...120 range are 30 only.

- To select the group or the energy counter to be reset, press **↕**, the value will start to flash.
- Press **↕** to change the value. To scroll the value quickly, keep pressed **↕**.
- Confirm with **↕**, a new page for confirmation will be displayed.
- Press **↕** to change the flashing value, Y to confirm the reset, N to cancel. Confirm with **↕**.

From setup exit pages:

- Press **↕** to change the flashing value, Y to exit and save the settings, N to exit without saving, C to continue scrolling setup pages. Confirm with **↕**.

INFO PAGES

Up to 7 pages can be displayed to show details about:

- Metrological part firmware release (rE1)
- User interface firmware release (rE2)
- Metrological part checksum (CS1)
- User interface checksum (CS2)
- Communication type
- CT secondary full scale value (FSA)
- Set wiring mode (only PULSE/M-BUS model)

The fifth page is not displayed in case of PULSE model not combined with communication module.


TECHNICAL FEATURES

The technical features can change according to the device model.



GENERAL	
Housing in compliance with standard	DIN 43880
Terminals in compliance with standard	EN 60999
POWER SUPPLY	
Power supplied from the voltage circuit	✓
Voltage range	3x230/400...3x240/415 V ±20%
Max consumption (for each phase) for PULSE and M-BUS models	7,5 VA - 0,5 W
Max consumption (for each phase) for RS485 MODBUS & ETHERNET models	3,5 VA - 1 W
CT burden for each phase	0,04 VA
Nominal frequency	50/60 Hz
CURRENT	
Starting current I _s	2 mA
Minimum current I _{min}	10 mA
Transitional current I _t	50 mA
Reference current I _r (I _n)	1 A
Maximum current I _m	6 A
CURRENT TRANSFORMER AND FSA	
Minimum CT ratio	1
Maximum CT ratio	10000
FSA programmable	1 or 5 A
ACCURACY	
Active en. class B in compliance with	EN 50470-3 (MID)
Active en. class 1 in compliance with	EN 42053-21 (NO MID)
Reactive en. class 2 in compliance with	EN 42053-23
COMMUNICATION for RS485 MODBUS model	
In compliance with standard	EIA RS485
Isolated port	✓
Unit load	1/8
Protocols	MODBUS RTU/ASCII
Communication speed	300...9600 bps
COMMUNICATION for M-BUS model	
In compliance with standard	EN 13757-1-2-3
Isolated port	✓
M-BUS	✓
Unit load	1
Protocols	M-BUS
Communication speed	300...9600 bps
COMMUNICATION for ETHERNET model	
In compliance with standard	IEEE 802.3
Isolated port	✓
Protocols	MODBUS/TCP, HTTP, NTP, DHCP
Communication speed	10/100 Mbps
50 OUTPUTS	
Passives optoisolated	✓
Max values for PULSE model (in compliance with EN 42053-31)	250 VAC-DC - 100 mA
Max values for RS485 MODBUS, M-BUS, ETHERNET models (in compliance with EN 42053-31)	27 VDC - 27 mA
Meter constant according to the set CT ratio. The measuring unit [imp/kWh, imp/kvarh, imp/kVAh] changes according to the assigned counter [kWh], [kvarh], [kVAh].	1000 → CT = 1...4 200 → CT = 5...24 40 → CT = 25...124 8 → CT = 125...624 1 → CT = 625...3124 0,1 → CT = 3125...10000
Pulse length	50 ±2ms ON time min. 30 ±2ms OFF time
TARIFF INPUT (NO ETHERNET model)	
Active optoisolated	✓
Voltage range for Tariff 2 (T2)	80...276 VAC-DC
METROLOGICAL LED	
Meter constant	10000 imp/kWh
WIRE SECTION FOR TERMINALS AND FASTENING TORQUE	
Measuring terminals (A & V)	1,5...4 mm ² / 1,5 Nm
50 output, tariff, port terminals	0,14...2,5 mm ² / 0,5 Nm
SAFETY ACCORDING TO EN 50470-1	
Pollution degree	2
Protective class (EN 50470-1)	II
Pulse voltage test	1,2 / 50 µs 6 kV
AC voltage test (EN 50470-3, 7.2)	4 kV
Housing material flame resistance	UL 94 class V0
ENVIRONMENTAL CONDITIONS	
Mechanical environmental	M1
Electromagnetic environmental	E2
Operating temperature	-25°C ... +55°C
Storage temperature	-25°C ... +75°C
Humidity (without condensation)	max 90%
Sinusoidal vibration amplitude	50 Hz ±0,075 mm
Protection degree - frontal part (granted only in case of installation in a cabinet with at least IP51 protection degree)	IP51
Protection degree - terminals	IP20
INTERNAL USE	✓

PICTURE/FIGURE


A




B




C




D




E




F




G




H




I




J




L



M



N



O

